

# Evidence of Performance

Compatibility with adjoining building materials -  
Component test as per ift-Guideline MO-01/1, Clause  
4.5

Test Report 105 34243/5e



Client **ROBITEX GROUP**  
Mojajskoe shosse 25

121471 Moscow  
Russia

Product Joint sealing tape for external watertight sealing of connecting joints

Designation **ROBIBAND NL**

Dimension (b x d) 100 mm x 0.15 mm

Material Textured double-sided self-adhesive polymer film consisting of double-sided acrylate-based adhesive tape and butyl rubber tape

Special features -/-

## Basis

ift-Guideline MO-01/1  
Connection between window and building fabric,  
Part 1: Method for determining the suitability for purpose of sealing systems, 2007-01

## Representation



## Instruction for use

This test report serves to demonstrate the above-mentioned characteristics  
ift-Guideline MO-01/1 : 2007-01

## Validity

The data and results refer solely to the tested and described specimen.  
The test does not allow any statement to be made on further details of the present structure and quality of the tested specimen.

## Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

## Contents

The test report comprises a total 6 pages.

- 1 Object
- 2 Procedure
- 3 Detailed results



Test as per MO-01/1 Clause	Requirements according to MO-01/1	Test results
4.5	<b>Compatibility with adjoining building materials (up to +60 °C)</b> No changes that impact on functional performance; no visual impairment of the product and adjoining materials. Contact materials used: Rigid PVC, pine wood (coated with water-based transparent paint), pine wood (coated with water-based opaque paint), untreated concrete, brick, lime sand brick, anodised aluminium, powder-coated aluminium	<b>fulfilled</b>

ift Rosenheim  
16 March 2009

Karin Lieb, Dipl.-Ing. (FH)  
Head of Testing Department  
ift Centre Glass, Building Materials & Building Physics

Wolfgang Jehl, Dipl.-Ing. (FH)  
Test engineer  
ift Centre Windows & Facades



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
  
DAP-PL-0508 99  
DAP-ZE-2288 00  
TGA-ZM-15-93-00  
TGA-ZM-16-93-60