

Evidence of Performance

Compatibility with adjoining building materials -
Component test as per ift-Guideline MO-01/1, Clause
4.5

Test Report 105 34243/8e



Client **ROBITEX GROUP**
Mojayskoe shosse 25

121471 Moscow
Russia

Product Joint sealing tape for airtight sealing of internal connecting joints

Designation **ROBIBAND PB**

Dimension (b x d) 100 mm x 1,5 mm


Material Aluminium foil, glass fibre web, polymer film, butyl rubber tape

Special features -/-

Basis

ift-Guideline MO-01/1
Wall connection of windows,
Part 1: Method to determine the
suitability of use of sealing
systems, 2007-01

Representation



Instruction for use

This test report serves to demonstrate the above-mentioned characteristics
ift-Guideline MO-01/1 : 2007-01

Validity

The data and results refer solely to the tested and described specimen.
The test does not allow any statement to be made on further details of the present structure and quality of the tested specimen.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

Contents

The test report comprises a total 6 pages.

- 1 Object
- 2 Procedure
- 3 Detailed results



Test as per MO-01/1 Clause	Requirements according to MO-01/1	Test results
4.5	Compatibility with adjoining building materials (up to +50 °C) No changes that impact on functional performance; no visual impairment of the product and adjoining materials. Contact materials used: Rigid PVC, pine wood (coated with water-based transparent paint), pine wood (coated with water-based opaque paint), untreated concrete, brick, lime sand brick, anodised aluminium, powder-coated aluminium	fulfilled

ift Rosenheim
16 March 2009

Karin Lieb, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Glass, Building Materials & Building Physics

Wolfgang Jehl, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Giethl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkante PUZ-Stelle: BAY 18

DAP-PL-0808 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60