

**Evidence of Performance**  
Hygrothermal performance of building  
materials and products  
Determination of water vapour transmission  
properties as per DIN EN ISO 12572



Test Report 105 34243/3e

Client **ROBITEX GROUP**  
Mojayskoe shosse 25  
  
121471 Moscow  
Russia

**Basis**  
DIN EN ISO 12572 : 2001-09;  
Hygrothermal performance of  
building materials and products  
Determination of water vapour  
transmission properties

Product **Joint sealing tape**

Designation **ROBIBAND PB**

Order **Test according to DIN EN ISO 12572**

Representation



Measurements carried out in accordance with DIN EN ISO 12572 have revealed the following characteristics of ROBIBAND PB:



**Water vapour resistance factor**

**$\mu = 14120$**

**Water vapour diffusion-equivalent air layer thickness**

**$s_D = 21 \text{ m}$**

**Instruction for use**

This test report provides evidence of the water vapour transmission properties of building materials and products

**Validity**

The data and results refer solely to the tested and described specimen.

**Notes on publication**

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

**Contents**

The test report comprises a total 5 Pages

- 1 Object
- 2 Procedure
- 3 Detailed results
- 4 Summary

ift Rosenheim  
16 March 2009

Karin Lieb, Dipl.-Ing. (FH)  
Head of Testing Department  
ift Centre Glass, Building Materials & Building Physics

Irina Hausstetter, Dipl.-Ing. (FH)  
Test engineer  
ift Centre Glass, Building Materials & Building Physics



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
  
DAP-PL-0808 99  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-60